

LABORATORY ANALYSIS REPORT
Asbestos Identification Report

Report No: B13655-R1 **Report Date:** Wednesday, 22 March 2017
Client: The Property Inspectors **Analysed Date:** Wednesday, 22 March 2017
Client Address: 80 Victoria Road, **Laboratory Receival Date:** Wednesday, 22 March 2017
 Drummoyne, NSW, 2047 **Sampled Date:** Monday, 20 March 2017

Attention: Ashleigh Wilson
Sampled From: 1/124 Kurraba Road Kurraba Point **NATA Approved Identifier and Signatory:** Jeffrey Sargent
 NSW 2089

Test Method: Polarised Light Microscopy (PLM) including Dispersion Staining (DS), Regional EnviroScience in house laboratory method, in accordance with Australian Standard AS4964-2004 'Method for the qualitative identification of asbestos in bulk samples'

Sample Number	Sample Size	Sample Location	Sample Description	Asbestos Detected	Fibres Detected
B13655-S1	3.8 gm	Roof Space	Insulation	No	Synthetic Mineral

SAMPLE



WORLD RECOGNISED
ACCREDITATION
No. 19366



Accredited For
Compliance With
International
Organisation For
Standardisation
ISO/IEC 170251



DUBBO
Unit 2/7 Energy Place
Dubbo NSW 2830
(02) 6884 8820

WAGGA WAGGA
Unit 2/2 Riedell Street
Wagga Wagga 2650
(02) 6925 9727

TAMWORTH
4/158 Marius Street
Tamworth NSW 2340
(02) 6761 2976



Regional EnviroScience Pty LTD
ACN 157 918 262
Phone 1300 E-SCIENCE
enviroscience.com.au

